

Abstract of the Disclosure

A method for determining the nature of a ground fault in a floating direct voltage load powering context includes measuring the load voltage and the current at a nominal balance point, both before and after closing a circuit to the load. The fault resistance and the fault voltage are determined as the solution to an equation in two unknowns given the conditions before and after application of load voltage or at least precharge.